



FORM - D

FORM OF LICENCE UNDER SUB-SECTION (1) OF SECTION 6 OF THE TAMIL NADU PUBLIC BUILDINGS (LICENSING) ACT, 1965 (TAMIL NADU ACT 13 OF 1965) REFERRED TO IN RULE 6 OF THE TAMIL NADU PUBLIC BUILDINGS (LICENSING) RULES, 1966

LICENCE

Licence No. TN-8720241121102

Date: 27-11-2024

Public Building Licence is hereby granted to **Thiru Karthikrishnan P** son of Thiru Pandurangan now residing at 52, Kamarajar street walaja Wallajah Revenue Village, Walajah Taluk, Ranipet District - 632513 of Tamil Nadu State for the purpose and in respect of the building specified in the statement below and subject to the conditions and for the period mentioned hereunder,

STATEMENT TO ACCOMPANY THE LICENCE

Location of the Building (Door number, Street Number & Name of the Place)	Purpose for which the building is licensed to be used as public building	Number of persons to be accommodated
55 Santhiya karthik krishnan educational trust edify world school sholingur road Chithathur, Sholingur, Ranipet, Tamil Nadu, 632501	School (including tutorial school)	1240

Fee paid Rs. 1000.0 vide Challan No: 202415959505, Dated: 20-11-2024

The Period of validity of the licence shall be from the 27-11-2024 to the 26-11-2027 inclusive

Signature valid

Digitally signed by **R SELVI**

Date: 27/11/2024 20:11:17 IST

District : Ranipet

LICENCE ISSUING AUTHORITY

This certificate is digitally signed and does not require any seal / signature in original.



Genuineness of the certificate can be verified by.

(a) Keying in the unique certificate number TN-8720241121102 in the URL <https://tnedistrict.tn.gov.in/tneda/VerifyCerti.xhtml>.

(or)

(b) Reading the 2D barcode with mobile barcode reader and verify through online.

Certificate validity period : 27-11-2024 to 26-11-2027

CORRESPONDENT
Edify World School,
Ranipet.

BUILDING SAFETY CERTIFICATE

No. 04/PE - Vellore

Dated: 25.04.2024 ✓


It is certified that the existing building **Edify World School at No.55, Chithathur Village, Walaja to Sholingur Road, Sholingur Taluk, Ranipet – 632501** is having block(s)/Floor(s) as per details below:


Detail of Block(s) in school	Block (1)	Block (2)	Block (3)	Block (4)	Block (5)	Block (6)
No. of Floor(s) in the Block	Zero basement and Ground + two Floor	NIL	NIL	NIL	NIL	NIL

The building is owned/occupied by **Edify World School** running under **Santhiya Karthik Krishnan Educational Trust** have complied with the Building safety requirements in accordance with National code Rules, and verified by the officers concerned of **Er. D. Natarajan**, on **09.04.2024** (date of inspection) in the presence of **Mr. P.Karthik Krishnan (Correspondent)**, **Edify World School at No.55 Chithathur village, Walaja to Sholingur main road, Sholingur Taluk, Ranipet -632501** and that the building/premises is fit for running school with effect from **01.06.2024** for a period of **Three** years from 01.06.2024 to 30.05.2027 in accordance with rule and subject to compliance of the specific conditions as appended.

1. Periodical maintenance of buildings are to be carried out
2. Periodical Fire Safety Certificate and Sanitary Certificate are to be obtained from the concerned authorities

Issued on **25.04.2024** at **Arakkonam** by


CORRESPONDENT
Edify World School,
Ranipet.


Signature with Seal
Er. D. NATARAJAN, B.E., (CIVIL) MIE
Chartered Engineer
Panel Engineer
Vellore District
50A, 3rd Street,
S.S. Nagar, Palanipet,
Arakkonam-631 002
Cell: 94431 06470, 8056631312

Er. D.NATARAJAN, B.E.(CIVIL),M.I.E.,
STRUCTURAL ENGINEER, CHARTERED ENGINEER
REGISTERED&APPROVED ENGINEER
BY THE BOARD OF ENGINEERS, TAMIL NADU.
PANEL ENGINEER CLASS IA, VELLORE DISTRICT

Res cum off : 50-A,3rd Street,
Somasundaram Nagar.
Palanipet,
Arakkonam – 631002

Cell: 9443106470, 8056631312
Email : dnatarajan8@gmail.com

Ref: Collector, VLR Lr. No. ந.க.அ.6/31531/2013 Dated : 23.09.2015

STRUCTURAL SOUNDNESS CERTIFICATE RELATING TO SCHOOL
STATEMENT ACCOMPANYING FORM - A

1. Name of the School and Door no of the Building : **SANTHIYA KARTHIK KRISHNAN EDUCATIONAL TRUST
EDIFY WORLD SCHOOL BUILDING,**
No. 55, Chithathur Village, Walajah to Sholinghur Road,
Sholinghur Taluk, Ranipet District – 632 501
2. Location (street No. Ward No. Name of place, ie., Corporation, Municipality/ Panchayat Union/ Panchayat/Township/Cantonment : S.F.No. 127/2B,
No. 55, Chithathur Village,
Walajah to Sholinghur Road,
Sholinghur Taluk, Ranipet District – 632 501.
3. Year of construction : Ground, First & Second Floor : RCC : 2024
4. Approximates cost of construction as per current rate : Rs. 950.00 Lakhs
5. Purpose for which the building is being used or proposed to be used : Educational Purpose
6. Purpose for which the building has hitherto been used : Educational Purpose
7. Details of construction of the building (particulars of the foundation, soil, Specification of various parts under : **RCC Framed Structure**
(i) Foundation : RCC Column & Footing
(ii) Basement : RCC Column, Plinth Beam & Brick in CM
(iii) Superstructure : RCC Column & Brick in CM
(iv) Floor & Roof are to be given : Flooring: Vitrified Tiles
Roof: RCC Slab
8. Period for which the license is require : May be issued FROM **01.06.2024 to 31.05.2027**
(For Three years only)
9. Number of persons to be accommodated Refer "ANNEXURE" to this : **One Thousand Two Hundred Forty (1240) Pupils only**

Place : Arakkonam

Date : 25.04.2024

Signature of the Correspondent

CORRESPONDENT
Edify World School,
Ranipet.

Signature of the Engineer
Er. D. NATARAJAN, B.E.,(CIVIL)MIE

Chartered Engineer
Panel Engineer
Vellore District
50A, 3rd Street,
S.S. Nagar, Palanipet,
Arakkonam-631 002
Cell: 94431 06470, 8056631312



மரம் வளர்ப்போம்.

மழை பெறுவோம்

ANNEXURE TO "STATEMENT ACCOMPANYING FORM – A"

Certified that no addition or alteration has been made to the existing building or portion of a building for which this application has been made. I undertake to obtain a fresh license in case any addition or alteration is made to the existing building or portion of the building. I also undertake to obtain a fresh license if the purpose for which the license was granted for the use of the building or portion of the building originally is change or altered subsequently.

This is further to certify that no thatched buildings are used for conducting any classes within the School premises. Any thatched building constructed/used after issue of this certificate, I would be held responsible for fire accident/mishap that may occur later and that I am aware that it is a punishable crime.

Signature of the Correspondent

CORRESPONDENT
Edify World School,
Ranipet.

Er. D.NATARAJAN, B.E.(CIVIL),M.I.E.,
STRUCTURAL ENGINEER, CHARTERED ENGINEER
REGISTERED&APPROVED ENGINEER
BY THE BOARD OF ENGINEERS, TAMIL NADU.
PANEL ENGINEER CLASS 1A, VELLORE DISTRICT

Res cum off : 50-A,3rd Street,
Somasundaram Nagar.
Palanipet,
Arakkonam – 631002
Cell: 9443106470, 8056631312
Email : dnatarajan8@gmail.com

FORM – B

STATEMENT ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS
SANTHIYA KARTHIK KRISHNAN EDUCATIONAL TRUST – EDIFY WORLD SCHOOL BUILDING,
CHITHATHUR VILLAGE

FORM OF CERTIFICATE OF STRUCTURAL SOUNDNESS UNDER TAMILNADU COMBINED
DEVELOPMENT AND BUILDING RULES 2019.

I Certify, that I have inspected the building mentioned in the statement and furnished below its
salient technical features.

1. Foundation:


- | | | |
|------|--|-------------------|
| i. | Depth below ground level | : 06 ft below G.L |
| ii. | Nature of soil met out in the foundation | : Hard Soil |
| iii. | Pressure at foundation | : 11 tones / Sq.m |
| iv. | Probable safe bearing capacity of the foundation | : 18 tones / Sq.m |

2. Superstructure:

- | | | | |
|-----|----------------------------------|------------------------|--------------------|
| i. | Maximum stress in most critical | a) R.C.C Concrete | : 35 Kg / Sq.cm |
| | Sections of masonry and concrete | b) Masonry | : 08 tones / Sq.m. |
| ii. | Nature of masonry and concrete | : Brick masonry in cm: | 30 tones / Sq.m. |
| | And its safe permissible stress | R.C.C | : 40 Kg / Sq.cm. |

The Structural of the building has been verified by me with reference to ISIS loading standards 875
(Latest version) and other relevant Indian Standard code of practices I declare that the building is
structurally sound to be used as a public building for the purpose noted in the statement. This Certificate
does not include any Thatched sheds and also any flammable building material utility. Proper toilet
facilities to be provided as per norms. If any thatched sheds are found at a later period after issue of this
certificate / License this certificate gets invalid. A license may be granted for the period from **01.06.2024 to**
31.05.2027.


Signature of the Correspondent
CORRESPONDENT
Edify World School,
Ranipet.


Signature of the Engineer
Er. D. NATARAJAN, B.E.,(CIVIL)-MIE
Chartered Engineer
Panel Engineer
Vellore District
50A, 3rd Street,
S.S. Nagar, Palanipet,
Arakkonam-631 002
Cell: 94431 06470, 8056631312

மரம் வளர்ப்போம்.

மழை பெறுவோம்

Er. D.NATARAJAN, B.E.(CIVIL),M.I.E.,
STRUCTURAL ENGINEER, CHARTERED ENGINEER
REGISTERED&APPROVED ENGINEER
BY THE BOARD OF ENGINEERS, TAMIL NADU.
PANEL ENGINEER CLASS IA, VELLORE DISTRICT

Res cum off : 50-A,3rd Street,
Somasundaram Nagar.
Palanipet,
Arakkonam – 631002
Cell: 9443106470, 8056631312
Email : dnatarajan8@gmail.com

FORM – C

STATEMENT ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS
SANTHIYA KARTHIK KRISHNAN EDUCATIONAL TRUST – EDIFY WORLD SCHOOL BUILDING,
CHITHATHUR VILLAGE

Form of certificate of structural soundness under Tamilnadu Combined Development and Building Rules 2019.

Certify that have inspected the building mentioned in the statement below and I have satisfied myself the building is structural sound to be used as a public building for the purpose note in the statement. The structural soundness of the building has been verified taking into account the loading as per latest Indian standard 875.

Location of the building door No. street name and name of the place	Age of the building	Value of the Building	No. of Storeys	Short Description of structure steel RCC framed or load bearing masonry
1.	2.	3.	4.	5.
SANTHIYA KARTHIK KRISHNAN EDUCATIONAL TRUST – EDIFY WORLD SCHOOL BUILDING No. 55, Chithathur Village, Walajah to Sholinghur Road, Sholinghur Taluk, Ranipet District – 632 501.	<u>Ground, First & Second Floors :</u> RCC : NEW	Rs. 950.00 Lakhs	Ground Floor + 2	RCC Framed Structure

Purpose for which the building is certified for use	The Period for which the building will be structurally sound	No of the persons to be accommodated	Remarks
6.	7.	8.	9.
Educational Purpose	License may be issued for the period of Three Years from 01.06.2024 to 31.05.2027	1240 Pupils only	Building is structurally sound

Signature of the Correspondent
CORRESPONDENT
Edify World School,
Ranipet.

Signature of the Engineer
Er. D. NATARAJAN, B.E.,(CIVIL) MIE
Chartered Engineer
Panel Engineer
Vellore District
50A, 3rd Street,
S.S. Nagar, Palanipet,
Arakkonam-631 002
Cell: 94431 06470, 8056631312

மரம் வளர்ப்போம்.

மழை பெறுவோம்

Er. D.NATARAJAN, B.E.(CIVIL),M.I.E.,
STRUCTURAL ENGINEER, CHARTERED ENGINEER
REGISTERED&APPROVED ENGINEER
BY THE BOARD OF ENGINEERS, TAMIL NADU.
PANEL ENGINEER CLASS IA, VELLORE DISTRICT

Res cum off : 50-A,3rd Street,
Somasundaram Nagar.
Palanipet,
Arakkonam – 631002
Cell: 9443106470, 8056631312
Email : dnatarajan8@gmail.com

FORM – E

STATEMENT ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS
SANTHIYA KARTHIK KRISHNAN EDUCATIONAL TRUST – EDIFY WORLD SCHOOL BUILDING,
CHITHATHUR VILLAGE

Form of report to be made to the competent authority by inspecting authorities or officers under Tamilnadu Combined Development and Building Rules 2019.


- | | | |
|--|---|---|
| 1. Name and Designation of inspecting authority or officer appointed or having jurisdiction under any other Act or law. | : | Er. D.NATARAJAN, B.E. (CIVIL), M.I.E.
STRUCTURAL ENGINEER, CHARTERED ENGINEER
REGISTERED & APPROVED ENGINEER
BY THE BOARD OF ENGINEERS, TAMILNADU.
PANEL ENGINEER CLASS IA,
VELLORE DISTRICT |
| 2. Location of the building inspected (Door Number, Street Number, Name of place, i.e. Municipal Corporation / Municipality / Panchayat or Panchayat Union/Township/Cantonment.) | : | S.F.No. 127/2B
No. 55, Chithathur Village,
Walajah to Sholinghur Road,
Sholinghur Taluk,
Ranipet District – 632 501. |
| 3. Date of Inspection | : | 09-04-2024 |
| 4. Purpose for which the building is used | : | Educational |
| 5. Nature of defects noticed | : | No defects found |
| 6. Suggestions for rectifying defects | : | Nil |
| 7. If in a dangerous condition, immediate Steps recommended to be taken | : | Nil |


CORRESPONDENT
Edify World School,
Ranipet.


Signature of the Engineer
Er. D. NATARAJAN, B.E.,(CIVIL) MIE
Chartered Engineer
Panel Engineer
Vellore District
50A, 3rd Street,
S.S. Nagar, Palanipet,
Arakkonam-631 002
Cell: 94431 06470, 8056631312

மரம் வளர்ப்போம்.

மழை பெறுவோம்



12.05.2025
TAMILNADU

EDIFY WORLD SCHOOL

EG 844740

G. கனகசபை
ததிரைத்தாள் விற்பனையாளர்
3605/2005.
வாலாஜா, ரா.மா., தமிழ்நாடு

Translated Copy

Proceedings of the Vellore District Collector

Presence: R. Nandagopal, I.A.S.

No: A6/31531/2013

Order: Date: 23.09.2015

Subject: Tamil Nadu Public Buildings Entitlement Rule 1965, Vellore District - Regarding the order to include Mr. D. Natrajan in the District Engineers List from Class 1 to Class 1A.

Reference:

1. Petition dated 17.11.2013 from Mr. D. Natrajan, Arcot, Vellore District.
2. Letter No. D.2/F:20 P.E./2014/463M/, dated 09.12.2014, from the Superintending Engineer, Public Works Department, Buildings (Construction and Maintenance) Circle, Vellore.
3. This office letter No. A6/31531/2013, dated 10.02.2015.



N. LAKSHMI NARASIMHAN
ADVOCATE & NOTARY PUBLIC
Enroll No. Ms.909/2001
No. 69, KAMARASAR STREET,
WALAJAPET - 632 513, VELLORE DT.,
Cell : 98947 46852

4. Letter No. AEE/T1/AE/25869/2015, dated 06.07.2015, from the Principal Chief Engineer (General), Public Works Department, Chennai.

Engineer Mr. D. Natrajan, residing at No. 50A, 3rd Street, Somasundaram Nagar, Palanippettai, Arcot, Vellore District, has requested in his petition (reference 1) to upgrade his name to Class 1A in the Vellore District Engineers List.

Regarding this petition, a report was requested from the Vellore Public Works Department Superintending Engineer. In the letter (reference 2), the report was received, and the Principal Chief Engineer, Public Works Department, Chennai, was requested in the letter (reference 3) to include the individual's name in the Vellore District Engineers List from Class 1 to Class 1A.

Accordingly, in the letter from the Chennai Principal Chief Engineer (reference 4), it was recommended and reported that the individual could be included as a self-employed engineer in Class 1A in the Vellore District Engineers List.

Therefore, Engineer Mr. D. Natrajan, residing at No. 50A, 3rd Street, Somasundaram Nagar, Palanippettai, Arcot, Vellore District, is hereby ordered under the Tamil Nadu Public Buildings Ownership Rules 1965, as a self-employed engineer in Vellore District (Class 1A - for buildings with a value above Rupees Fifty Lakhs).

For District Collector,
Vellore - 09.

To:

Mr. D. Natrajan,

No. 50A, 3rd Street,

Somasundaram Nagar,

Palanippettai, Arcot - 631002.

Copy to:

1. Superintending Engineer, Public Works Department, Buildings (Construction and Maintenance), Vellore.
2. Principal Chief Engineer (General), PWD, Chepauk, Chennai - 600005.



N. LAKSHMI NARASIMHAN
ADVOCATE & NOTARY PUBLIC
Enroll No. Ms.909/2001
No. 69, KAMARASAR STREET,
WALAJAPET - 632 513, VELLORE DT.,
Cell : 98947 46852